



Certificate number: 2404731 (1)

Issued 25/04/2024 Expires 25/04/2029

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a) Model number(s) – see Appendix

Apator Powogaz S.A.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

DAY.

David Jay, Business Unit Manager – Authorised Signatory Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply. See https://www.kiwa.com/gb/en/about-kiwa/water-products/ or the QR code below to ensure that the certificate is still valid.

Kiwa Watertec

(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD

United Kingdom

T +44 (0)1495 308185

uk.water@kiwa.com

www.kiwa.co.uk

Certificate Issued to:

Apator Powogaz S.A Jaryszki 1c Zerniki 62-023 Poland





Product Certificate



Appendix to Certificate number: 2404731

The following products belong to this certificate

PRODUCT DESCRIPTION

Ultrims Ultrasonic range of in-line water meters with brass or plastic bodies and plastic turbines

ATS3 - Without Production Surveillance.

MODEL(S)

UL 2.5 (port lengths 80, 110 & 165mm),

UL 2.5-01 (port lengths 80 & 110mm),

UL 4 (port lengths 105, 115, 130 & 190mm),

UL 4-01 (port lengths 105 & 130mm),

UL 6.3 (port lengths 165 & 260mm),

UL 25 (port lengths 200, 270 & 300mm).

SIZE:

3/4" BSP (M), 1" BSP (M), 11/4" BSP (M). DN50 flanged connection.

SCOPE:

Manufacturer recommended maximum working pressure 16 Bar & maximum operating temperature 50°C.

Hygienic Purposes: Non-metallic materials suitable for continuous use up to 50°C.

MARKING

Powogaz logo, manufacturer's address and year YYYY, CE Mark, meter type and other technical information on meter face. Flow arrow on body.

MATERIALS

Non-metallic materials assessed (BS6920) to point of discharge/to backflow prevention device.

BACKFLOW PROTECTION NOTES

N/A.

ADDITIONAL NOTES

All water contact & exposed components satisfy opacity requirements.

Extra Notes